



BANGLADESH-CHINA POWER COMPANY LIMITED

(A Joint Venture of CMC and NWPGCL)

UTC Building (Level # 5), 8 Panthapath, Kawran Bazar, Dhaka-1215, Bangladesh
Phone No. 9143908, 9140757, Web: www.bcpcl.org.bd, E-mail:info@bcpcl.org.bd

REQUEST FOR QUOTATION

for

**Procurement of Urgent Electrical spare items required for Coal Handling
Plant of Payra 1320MW TPP site of BCPCL.**

BANGLADESH-CHINA POWER COMPANY LIMITED

(A Joint Venture of CMC and NWPGCL)

**UTC Building (Level-05), 8 Panthapath,
Kawran Bazar, Dhaka-1215, Bangladesh**

Issued Ref.: BCPCL/CHPMD/RFQ/2025-26/007

Issued On: February 16, 2026

Submission Deadline: February 23, 2026 11:00 AM





BANGLADESH-CHINA POWER COMPANY LIMITED

(A Joint Venture of CMC and NWPGL)

UTC Building (Level # 5), 8 Panthapath, Kawran Bazar, Dhaka-1215, Bangladesh
Phone No. 9143908, 9140757, Web: www.bcpcl.org.bd, E-mail:info@bcpcl.org.bd

REQUEST FOR QUOTATION

for

**Procurement of Urgent Electrical spare items required for Coal Handling Plant of Payra
1320MW TPP site of BCPCL.**

Issued Ref.: BCPCL/CHPMD/RFQ/2025-26/007


Issued On: **February 16, 2026**

To

1. **Bangladesh-China Power Company Limited** has been allocated funds and intends to apply a portion of the funds to eligible payments under the Contract for which this Quotation Document is issued.
2. Detailed Specifications and Design & Drawings for the intended Works and physical services are available in the office of the Procuring Entity for inspection by the potential Quotations during office hours on all working days.
3. Quotation shall be prepared and submitted using the ' RFQ Document' .
4. Quotation shall be completed properly, duly signed-dated each page by the authorized signatory and submitted by the date to the office as specified in Para 6 below.
5. Securities such as Quotation Security (i.e. the traditionally termed Earnest Money, Tender Security) shall not be required for submission of the Quotation and delivery of the Goods (if awarded) respectively.
6. Quotation in a sealed envelope or by fax or through electronic mail on or before **11:00 AM on February 23, 2026**. The envelope containing the Quotation must be clearly marked "**REQUEST FOR QUOTATION for Procurement of Electrical urgent spare items required for Coal Handling Plant of Payra 1320MW TPP site of BCPCL.**" and "**DO NOT OPEN before 11:30 AM. on February 23, 2025**". Quotations received later than the time specified herein shall not be accepted.
7. Quotations received by fax or through password protected electronic mail or hard copy shall be sealed-enveloped by the Procuring Entity duly marked as stated in Para 6 above and, all Quotations thus received shall be sent to the Evaluation Committee for evaluation, without opening, by the same date of closing the Quotation.
8. The Procuring Entity may extend the deadline for submission of Quotations on justifiably acceptable grounds duly recorded subject to threshold of ten (10) days.
9. Quotation shall be submitted as per Price Schedule of Goods and Services.



10. All Quotations must be valid for a period of at least 60 (Sixty) days from the closing date of the Quotation.
11. No public opening of Quotations received by the closing date shall be held.
12. Quotationer's rates or prices shall be inclusive of profit and overhead and, all kinds of taxes, duties, fees, levies, and other charges to be paid under the Applicable Law, if the Contract is awarded.
13. Rates shall be quoted and, subsequent payments under this Contract shall be made in BDT. The price offered by the Quotationer, if accepted shall remain fixed for the duration of the Contract.
14. Quotationer shall have legal capacity to enter into Contract. Quotationer, in support of its qualification shall be required to submit certified photocopies of the following documents:
 - i. Valid Trade License,
 - ii. Tax Identification certificate
 - iii. VAT Registration certificate
 - iv. Bank Solvency Certificate
 Failure to submit such documents shall cause rejection of Quotation,
15. Quotations shall be evaluated based on information and documents submitted with the Quotations, by the Evaluation Committee and, at least three (3) responsive Quotations will be required to determine the lowest evaluated responsive Quotations for award of the Contract.
16. In case of anomalies between unit rates or prices and the total amount quoted, the unit rates or prices shall prevail. In case of discrepancy between words and figures the former will govern. In case of quotation submitted on Lump-sum basis, if anomalies found between figures and words, the words will prevail. Quotationer shall remain bound to accept the arithmetic corrections made by the Evaluation Committee.
17. The supply of Goods and related services shall be completed within **21 days** from the date of issuing the Purchase Order.
18. Bidders must specify the Brand and Model of the offered items (where applicable) and provide a clear and detailed description of the product. Failure to do so will render the tender Technically Non-Responsive. Any generic remarks such as "**As Per Requirement**," "**As Per Tender Document**," or similar statements in the Technical Specification of the Goods Required section will not be accepted and will result in the bid being considered **Technically Non-Responsive**.
19. The Purchase Order that constitutes the Contract binding upon the Supplier and the Procuring Entity shall be issued within **03 days** of receipt of approval from the Approving Authority.
20. The Procuring Entity reserves the right to reject all the Quotations or annul the procurement proceedings.


16.02.2026

Nazmul Hasan

Executive Engineer (CHP)
 Bangladesh-China Power Company Limited
 Payra Thermal Power Plant, Kalapara, Patuakhali.
 e-mail: nazmul@bcpcl.org.bd

Distribution:

1. BCPCL website.
2. Office File.



Quotation Submission Letter

Issued Ref.: BCPCL/CHPMD/RFQ/2025-26/007

Issued On: February 16, 2025

Executive Engineer (CHP)
Bangladesh-China Power Company Limited
Payra Thermal Power Plant, Kalapara, Patuakhali.

I/We, the undersigned, offer to execute in conformity with the Conditions of Contract for execution of the Works and physical services named **Procurement of Urgent Electrical spare items required for Coal Handling Plant of Payra 1320MW TPP site of BCPCL**.

The total Price of my/our Quotation is BDT

In Words:

My/Our Quotation shall remain valid for the period stated in the RFQ Document and it shall remain binding upon us and, may be accepted at any time prior to the expiration of its validity period.

I/We declare that I/we have the legal capacity to enter into a contract with you, and have not been declared ineligible by the Government of Bangladesh on charges of engaging in corrupt, fraudulent, collusive or coercive practices. Furthermore, I/we am/are aware of Para 19(b) of the Terms and Conditions and pledge not to indulge in such practices in competing for or in executing the works.

I/We am/are not submitting more than one Quotation in this RFQ process in my/our own name or other name or in different names. I/We understand that your written invitation to sign the Contract shall become binding upon us, until a formal Contract is signed.

I/We have examined and have no reservations to the RFQ Document issued by you on **February 16, 2026**.

I/We understand that you reserve the right to reject all the Quotations or annul the procurement proceedings without incurring any liability to me/us.

Signature of Quotator with Seal
Date:



Price Schedule of Goods & Related Services

Issued Ref: BCPCL/CHPMD/RFQ/2025-26/007

Issued On: February 16, 2026

Sl. No	Item Name	Specification	Unit	Quantity	Unit Price including VAT & IT (BDT)	Total Price including VAT & IT (BDT)
1	2	3	4	5	6	7
01	Fire Emergency Light	Fire Emergency Light Model: YD-ZFZD-E3WA Input Voltage: 220V, 50Hz Excuton Standard: GB 17945-2010 Brand: Yilida	Pcs	6		
02	Miniature Circuit Breaker (C-2P-6A)	Miniature Circuit Breaker Model: IC65N C 6A Rated Current: 6 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	10		
03	Miniature Circuit Breaker (C-2P-10A)	Miniature Circuit Breaker Model IC65N C 10A Rated Current: 10 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	10		
04	Miniature Circuit Breaker (C-2P-16A)	Miniature Circuit Breaker Model: IC65N C 16A Rated Current: 16 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	10		
05	Miniature Circuit Breaker (C-3P-25A)	Miniature Circuit Breaker IC65N C 25A Rated Current: 25 A No of Pole: 3 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	10		
06	Miniature Circuit Breaker (C-3P-32A)	Miniature Circuit Breaker Model: IC65N C 32A Rated Current: 32 A No of Pole: 3 Tripping Curve: C All Screw and Contact Should be of	Pcs	10		



Sl. No	Item Name	Specification	Unit	Quantity	Unit Price including VAT & IT (BDT)	Total Price including VAT & IT (BDT)
1	2	3	4	5	6	7
		copper Brand: Schneider Electric Country Origin: Europe / USA				
07	Miniature Circuit Breaker (D-3P-50A)	Miniature Circuit Breaker Model: IC65N D 50A Rated Current: 50 A No of Pole: 3 Tripping Curve: D All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
08	Miniature Circuit Breaker (D-3P-63A)	Miniature Circuit Breaker Model: IC65N D 63A Rated Current: 63 A No of Pole: 3 Tripping Curve: D All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
09	Motor Protection Circuit Breaker (MPCB) GV2-ME05C / 0.63-1 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME05C / 0.63-1 A Thermal Protection Adjustment Range: 0.63-1 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
10	Motor Protection Circuit Breaker (MPCB) GV2-ME06C / 1-1.6 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME06C / 1-1.6 A Thermal Protection Adjustment Range: 1-1.6 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
11	Motor Protection Circuit Breaker (MPCB) GV2-ME07C / 1.6-2.5 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME07C / 1.6-2.5 A Thermal Protection Adjustment Range: 1.6-2.5 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		



Sl. No	Item Name	Specification	Unit	Quantity	Unit Price including VAT & IT (BDT)	Total Price including VAT & IT (BDT)
1	2	3	4	5	6	7
12	Motor Protection Circuit Breaker (MPCB) (GV2-ME08C / 2.5-4 A)	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME08C / 2.5-4 A Thermal Protection Adjustment Range: 2.5-4 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
13	Motor Protection Circuit Breaker (MPCB) GV2-ME10C / 4-6.3 A	Motor Protection Circuit Breaker (MPCB) GV2-ME10C / 4-6.3 A, Thermal Protection Adjustment Range: 4-6.3 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
14	Motor Protection Circuit Breaker (MPCB) GV2-ME14C / 6-10 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME14C / 6-10 A Thermal Protection Adjustment Range: 6-10 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
15	Motor Protection Circuit Breaker (MPCB) GV2-ME16C / 9-14 A	Motor Protection Circuit Breaker (MPCB) GV2-ME16C / 9-14 A, Thermal Protection Adjustment Range: 9-14 A All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	5		
16	Motor Protection Circuit Breaker (MPCB) GV2-ME20C / 13-18 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME20C / 13-18 A Thermal Protection Adjustment Range: 13-18 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	2		
17	Motor Protection Circuit Breaker (MPCB)	Motor Protection Circuit Breaker (MPCB) GV2-ME21C / 17-23 A, Thermal Protection Adjustment Range:	Pcs	5		



Sl. No	Item Name	Specification	Unit	Quantity	Unit Price including VAT & IT (BDT)	Total Price including VAT & IT (BDT)
1	2	3	4	5	6	7
	GV2-ME21C / 17-23 A	17-23 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA				
18	Leakage clamp on meter	Leakage clamp on meter Model 369 FC Manufacturer: Fluke	Pcs	1		
19	Electric tester pen	Electric tester pen Model No: 66-119 Screw Drive Type Size: 3 mm x 50 mm Color: Yellow Test Range - 100 V - 500. Brand: Stanley	Pcs	6		
20	Inspection Torchlight (Rechargeable)	Inspection Torchlight (Rechargeable) Model: F1P Rechargeable Battery: Rechargeable battery that integrates a Type-C interface for charging IP Rating: IPX7 Brand: BEEFLY/Equivalent	Pcs	2		
21	Motor Circuit Breaker GV3P 50 / 37-50 A	Motor Circuit Breaker GV3P 50 / 37-50 A Thermal Protection Adjustment Range: 37-50 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	2		
22	Magnetic contactor	Magnetic contactor Model: LC1D410 C Rated Current: 410 A Coil Voltage: 24V DC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	Pcs	2		
23	Magnetic contactor	Magnetic contactor Model: LC1D40 Rated Current: 40 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	Pcs	2		
24	Magnetic contactor	Magnetic contactor Model: LC1D40A Rated Current: 40 A	Pcs	2		



Sl. No	Item Name	Specification	Unit	Quantity	Unit Price including VAT & IT (BDT)	Total Price including VAT & IT (BDT)
1	2	3	4	5	6	7
		Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China				
25	Magnetic contactor	Magnetic contactor Model: LC1D95 Rated Current: 95 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	Pcs	2		
26	Magnetic contactor	Magnetic contactor Model: LC1D170 Rated Current: 170 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	Pcs	2		
27	Signal Fuse	Fuse Signal Breaker Model: RX1D 1000 Breaker UN-1000V Brand: Shanghai Electrical Ceramics Factory Co. Ltd.,	Pcs	5		
28	Magnetic Contactor	Magnetic Contactor Model: CAD32 BD Rated Current: 32 A Coil Voltage: 24V DC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	10		
29	Limit Switch	Limit Switch Model: WLCA2-G-N Brand: Omron	Pcs	6		
30	Three-phase circuit breaker	Three Phase Circuit Breaker Model: EA9AN3D63 3P 63A D type Brand: Schneider Electric Country Origin: Europe / USA	Pcs	10		
31	AC contactor	AC contactor Model: LC1D50B7C Rated Current: 50A Coil Voltage: 24V AC All Screw and Contact Should be of copper Brand: Schneider Electric	Pcs	10		



Sl. No	Item Name	Specification	Unit	Quantity	Unit Price including VAT & IT (BDT)	Total Price including VAT & IT (BDT)
1	2	3	4	5	6	7
		Country Origin: Czech Republic				
32	Motor Circuit Breaker	Motor Circuit Breaker GV3P65 / 48-65A Thermal Protection Adjustment Range: 48-65 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Pcs	2		
33	Angle grinder	Angle grinder Model: GWS1400-150 Input power: 1380W Grinding/slicing diameter: 150mm no-load speed: 9300 revolutions per minute Brand: Bosch Country Origin: Germany	Pcs	1		
Total Price Including VAT & TAX (BDT)						
In Words:						

Total Price Including VAT & IT (in words)	
Goods to be supplied to	Payra 1320MW TPP site, Dhankhali, Kalapara, Patuakhali.
Delivery offered	21 (Twenty-two) days from the date of issuing purchase order

[Insert number] number corrections made by me/us have been duly initialed in this BoQ.

Signature of the Quotator with Seal	Date:
Name of the Quotator	

Note:

1. Col. 1, 2, 3, 4 and 5 to be filled in by the Procuring Entity and Col. 6 & 7 by the Quotator.
2. Rates or Prices shall include profit and overhead and, all kinds of taxes, duties, fees, levies, and other charges earlier paid or to be paid under the Applicable Law, if the Contract is awarded; including transportation, load & unloading cost at delivery site, insurance etc. Whatsoever up to the point of delivery of Goods and related services in all respects to the satisfaction of the Procuring Entity



Technical Specification of the Goods & Related Services

Issued Ref: BCPCL/CHPMD/RFQ/2025-26/007

Issued On: February 16, 2026

Sl. No	Item Name	Specification	Specifications offered by the Tenderer (Must be filled Properly) (Must include Brand, if any)
1	2	3	4
01	Fire Emergency Light	Fire Emergency Light Model: YD-ZFZD-E3WA Input Voltage: 220V, 50Hz Excuton Standard: GB 17945-2010 Brand: Yilida	
02	Miniature Circuit Breaker (C-2P-6A)	Miniature Circuit Breaker Model: IC65N C 6A Rated Current: 6 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of Copper Brand: Schneider Electric Country Origin: Europe / USA	
03	Miniature Circuit Breaker (C-2P-10A)	Miniature Circuit Breaker Model IC65N C 10A Rated Current: 10 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
04	Miniature Circuit Breaker (C-2P-16A)	Miniature Circuit Breaker Model: IC65N C 16A Rated Current: 16 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
05	Miniature Circuit Breaker (C-3P-25A)	Miniature Circuit Breaker IC65N C 25A Rated Current: 25 A No of Pole: 3 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
06	Miniature Circuit Breaker (C-3P-32A)	Miniature Circuit Breaker Model: IC65N C 32A Rated Current: 32 A No of Pole: 3 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
07	Miniature Circuit Breaker (D-3P-50A)	Miniature Circuit Breaker Model: IC65N D 50A Rated Current: 50 A No of Pole: 3	



Sl. No	Item Name	Specification	Specifications offered by the Tenderer (Must be filled Properly) (Must include Brand, if any)
1	2	3	4
		Tripping Curve: D All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
08	Miniature Circuit Breaker (D-3P-63A)	Miniature Circuit Breaker Model: IC65N D 63A Rated Current: 63 A No of Pole: 3 Tripping Curve: D All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
09	Motor Protection Circuit Breaker (MPCB) GV2-ME05C / 0.63-1 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME05C / 0.63-1 A Thermal Protection Adjustment Range: 0.63-1 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
10	Motor Protection Circuit Breaker (MPCB) GV2-ME06C / 1-1.6 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME06C / 1-1.6 A Thermal Protection Adjustment Range: 1-1.6 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
11	Motor Protection Circuit Breaker (MPCB) GV2-ME07C / 1.6-2.5 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME07C / 1.6-2.5 A Thermal Protection Adjustment Range: 1.6-2.5 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
12	Motor Protection Circuit Breaker (MPCB) (GV2-ME08C / 2.5-4 A)	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME08C / 2.5-4 A Thermal Protection Adjustment Range: 2.5-4 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
13	Motor Protection Circuit Breaker (MPCB) GV2-ME10C / 4-6.3 A	Motor Protection Circuit Breaker (MPCB) GV2-ME10C / 4-6.3 A, Thermal Protection Adjustment Range: 4-6.3 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
14	Motor Protection Circuit Breaker (MPCB) GV2-ME14C / 6-10 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME14C / 6-10 A Thermal Protection Adjustment Range: 6-10 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric	



Sl. No	Item Name	Specification	Specifications offered by the Tenderer (Must be filled Properly) (Must include Brand, if any)	
1	2	3	4	
		Country Origin: Europe / USA		
15	Motor Protection Circuit Breaker (MPCB) GV2-ME16C / 9-14 A	Motor Protection Circuit Breaker (MPCB) GV2-ME16C / 9-14 A, Thermal Protection Adjustment Range: 9-14 A All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA		
16	Motor Protection Circuit Breaker (MPCB) GV2-ME20C / 13-18 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME20C / 13-18 A Thermal Protection Adjustment Range: 13-18 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA		
17	Motor Protection Circuit Breaker (MPCB) GV2-ME21C / 17-23 A	Motor Protection Circuit Breaker (MPCB) GV2-ME21C / 17-23 A, Thermal Protection Adjustment Range: 17-23 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA		
18	Leakage clamp on meter	Leakage clamp on meter Model 369 FC Manufacturer: Fluke		
19	Electric tester pen	Electric tester pen Model No: 66-119 Screw Drive Type Size: 3 mm x 50 mm Color: Yellow Test Range - 100 V - 500. Brand: Stanley		
20	Inspection Torchlight (Rechargeable)	Inspection Torchlight (Rechargeable) Model: F1P Rechargeable Battery: Rechargeable battery that integrates a Type-C interface for charging IP Rating: IPX7 Brand: BEEFLY/Equivalent		
21	Motor Circuit Breaker GV3P 50 / 37-50 A	Motor Circuit Breaker GV3P 50 / 37-50 A Thermal Protection Adjustment Range: 37-50 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA		
22	Magnetic contactor	Magnetic contactor Model: LC1D410 C Rated Current: 410 A Coil Voltage: 24V DC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China		



Sl. No	Item Name	Specification	Specifications offered by the Tenderer (Must be filled Properly) (Must include Brand, if any)
1	2	3	4
23	Magnetic contactor	Magnetic contactor Model: LC1D40 Rated Current: 40 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	
24	Magnetic contactor	Magnetic contactor Model: LC1D40A Rated Current: 40 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	
25	Magnetic contactor	Magnetic contactor Model: LC1D95 Rated Current: 95 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	
26	Magnetic contactor	Magnetic contactor Model: LC1D170 Rated Current: 170 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	
27	Signal Fuse	Fuse Signal Breaker Model: RX1D 1000 Breaker UN-1000V Brand: Shanghai Electrical Ceramics Factory Co. Ltd.,	
28	Magnetic Contactor	Magnetic Contactor Model: CAD32 BD Rated Current: 32 A Coil Voltage: 24V DC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
29	Limit Switch	Limit Switch Model: WLCA2-G-N Brand: Omron	
30	Three-phase circuit breaker	Three Phase Circuit Breaker Model: EA9AN3D63 3P 63A D type Brand: Schneider Electric Country Origin: Europe / USA	
31	AC contactor	AC contactor Model: LC1D50B7C	



Sl. No	Item Name	Specification	Specifications offered by the Tenderer (Must be filled Properly) (Must include Brand, if any)
1	2	3	4
		Rated Current: 50A Coil Voltage: 24V AC All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Czech Republic	
32	Motor Circuit Breaker	Motor Circuit Breaker GV3P65 / 48-65A Thermal Protection Adjustment Range: 48-65 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
33	Angle grinder	Angle grinder Model: GWS1400-150 Input power: 1380W Grinding/slicing diameter: 150mm no-load speed: 9300 revolutions per minute Brand: Bosch Country Origin: Germany	

(For reference photographs, kindly refer to Annexure-01, attached at the last page of the RFQ document)

***All products must be ORIGINAL and Quotations must include complete and clearly defined Technical Specifications, along with the exact Model and Brand Name for each item under the "Specifications offered by the Tenderer" section. Any omission, ambiguity, or failure to provide this information will result in the quotation being deemed technically non-responsive and will lead to immediate disqualification from further evaluation, without exception.**

***The items have been specified with particular manufacturers. The supplier must provide the exact specified brand and model as mentioned in the tender document. Products from any other manufacturer or alternative models shall not be accepted.**



**Purchase Order
FOR
Procurement of spare items required for Coal Handling Plant of Payra
1320MW TPP site of BCPCL**

Purchase Order No.:

Date:

To:

Purchase Order Value: BDT

Taka in words:

Completion date of delivery:

Delivery terms:

- (a) The items shall be supplied as per the instructions and supervision of BCPCL within the above completion date. BCPCL reserves the right to cancel the Purchase Order in case the supplier fails to supply the items within the stipulated date.
- (b) VAT/Taxes, as applicable, shall be deducted at source as per law;
- (c) Payment shall be made after satisfactory completion of supply and certification of Concerned Authority.
- (d) Goods shall be delivered as per approved specification.

Hence, you are requested to supply the below mentioned goods on the terms and conditions as stipulated in the Purchase Order.

Sl. No.	Item Description	Unit of Measurement	Qty	Unit Price in BDT (Including VAT & TAX)	Total Price in BDT (Including VAT & TAX)
Total Amount (BDT)					

Thanking you,

By the approval of authority,

(Nazmul Hasan)

Executive Engineer (CHP)

Bangladesh-China Power Company Limited
Payra Thermal Power Plant, Kalapara, Patuakhali.
e-mail: nazmul@bcpcl.org.bd



**Terms and Conditions
for
Procurement of spare items required for Coal Handling Plant of Payra 1320MW TPP site of
BCPCL**

1. Terms and Conditions contained herein shall be binding upon both the Procuring Entity and the Supplier for the purpose of administration and management of this Contract.
2. Implementation and interpretation of these Terms and Conditions shall, in general, be under the purview of Procurement Procedures of BCPCL.
3. The Supplier shall have to complete the delivery in all respects within **21 days** of issuing the Purchase Order in conformity with the Terms and Conditions.
4. The Supplier shall be entitled to an extension of the Delivery Schedule if the Procuring Entity delays in receiving the Goods and related services or if Force Majeure situation occurs or for any other reasons acceptable to the Procuring Entity on justifiable grounds duly recorded.
5. All delivery under the Contract shall at all times be open to examination, inspection, measurements, testing, commissioning, and supervision of the Procuring Entity or his/her authorized representative.
6. The Procuring Entity shall check and verify the delivery made by the Supplier in conformity with the Technical Specifications and notify the Supplier of any Defects found.
7. If the Goods are found to be defective or otherwise not in accordance with the specifications, the Procuring Entity may reject the supplies by giving due notice to the Supplier, with reasons.
8. The Supplier shall be entirely responsible for payment of all taxes, duties, fees, and such other levies under the Applicable Law.
9. Notwithstanding any other practice, the payment shall be based on the actual delivery of goods on the basis of the quantity of each item of Goods in accordance with the Priced Schedule and Specifications. 100% of the Contract price of the Goods and related services shall be paid after submission and acceptance of the Delivery Chalan.
10. The Supplier's rates or prices shall be inclusive of profit and overhead and, all kinds of taxes, duties, fees, levies, and other charges to be paid under the Applicable Law.
11. The total Contract **Price is BDT [insert figure] [in words]**.
12. The Supplier shall remain liable to fulfil the obligations under the Applicable Law.
13. The Supplier shall keep the Procurement Entity harmless and indemnify from any claim, loss of property or life to himself/herself, his/her workmen or staff, any staff of the Procurement Entity or any third party while delivering the Goods and related services.
14. Any claim arising out of delivery of Goods and related services shall be settled by the Supplier at his/her own cost and responsibility.
15. Damage to the Goods during the Warranty Period shall be remedied by the Supplier at the Supplier's own cost, if the damage arises from the supply and installation by the Supplier
16. No modification to Scope of Supply and no Variations to the quantities ordered shall be permissible under any circumstances.



17. The Procuring Entity contracting shall amend the Contract incorporating required approved changes subsequently introduced to the original Terms and Conditions in line with the applicable law, where necessary.
18. Tenderer shall make reasonable provisions for the occupational safety and health of himself/herself, his/her workmen or staff, any staff of the Procurement Entity or any third party while delivering the physical services.
19. The Procuring Entity may, by written Notice sent to the Supplier, terminate the Contract in whole or in part at any time, if the Supplier:
 - a. fails to deliver Goods and related services as per Delivery Schedule and Specifications.
 - b. in the judgement of the Procuring Entity, has engaged in any corrupt, fraudulent, collusive or coercive practices in competing for or in delivery of goods and related services.
 - c. fails to perform any other obligation(s) under the Contract.
20. The Procuring Entity and the Supplier shall use their best efforts to settle amicably all possible disputes arising out of or in connection with this Contract or its interpretation.
21. The Supplier shall be subject to, and aware of provision on corruption, fraudulence, collusion and coercion with the applicable law.



Annexure-01

SL	Name	Specification	Sample Picture
1	2	3	6
01	Fire Emergency Light	<p>Fire Emergency Light Model: YD-ZFZD-E3WA Input Voltage: 220V, 50Hz Execution Standard: GB 17945-2010 Brand: Yilida</p>	
02	Miniature Circuit Breaker (C-2P-6A)	<p>Miniature Circuit Breaker Model: IC65N C 6A Rated Current: 6 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of Copper Brand: Schneider Electric Country Origin: Europe / USA</p>	
03	Miniature Circuit Breaker (C-2P-10A)	<p>Miniature Circuit Breaker Model IC65N C 10A Rated Current: 10 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	
04	Miniature Circuit Breaker (C-2P-16A)	<p>Miniature Circuit Breaker Model: IC65N C 16A Rated Current: 16 A No of Pole: 2 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	




SL	Name	Specification	Sample Picture
1	2	3	6
05	Miniature Circuit Breaker (C-3P-25A)	<p>Miniature Circuit Breaker IC65N C 25A Rated Current: 25 A No of Pole: 3 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	
06	Miniature Circuit Breaker (C-3P-32A)	<p>Miniature Circuit Breaker Model: IC65N C 32A Rated Current: 32 A No of Pole: 3 Tripping Curve: C All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	
07	Miniature Circuit Breaker (D-3P-50A)	<p>Miniature Circuit Breaker Model: IC65N D 50A Rated Current: 50 A No of Pole: 3 Tripping Curve: D All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	
08	Miniature Circuit Breaker (D-3P-63A)	<p>Miniature Circuit Breaker Model: IC65N D 63A Rated Current: 63 A No of Pole: 3 Tripping Curve: D All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	



SL	Name	Specification	Sample Picture
1	2	3	6
09	Motor Protection Circuit Breaker (MPCB) GV2-ME05C / 0.63-1 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME05C / 0.63-1 A Thermal Protection Adjustment Range: 0.63-1 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
10	Motor Protection Circuit Breaker (MPCB) GV2-ME06C / 1-1.6 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME06C / 1-1.6 A Thermal Protection Adjustment Range: 1-1.6 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
11	Motor Protection Circuit Breaker (MPCB) GV2-ME07C / 1.6-2.5 A	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME07C / 1.6-2.5 A Thermal Protection Adjustment Range: 1.6-2.5 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
12	Motor Protection Circuit Breaker (MPCB) (GV2-ME08C / 2.5-4 A)	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME08C / 2.5-4 A Thermal Protection Adjustment Range: 2.5-4 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	



SL	Name	Specification	Sample Picture
1	2	3	6
13	Motor Protection Circuit Breaker (MPCB) GV2-ME10C / 4-6.3 A Thermal Protection Adjustment Range: 4-6.3 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Motor Protection Circuit Breaker (MPCB) GV2-ME10C / 4-6.3 A, Thermal Protection Adjustment Range: 4-6.3 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
14	Motor Protection Circuit Breaker (MPCB) GV2-ME14C / 6-10 A Thermal Protection Adjustment Range: 6-10 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME14C / 6-10 A Thermal Protection Adjustment Range: 6-10 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
15	Motor Protection Circuit Breaker (MPCB) GV2-ME16C / 9-14 A Thermal Protection Adjustment Range: 9-14 A All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Motor Protection Circuit Breaker (MPCB) GV2-ME16C / 9-14 A, Thermal Protection Adjustment Range: 9-14 A All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
16	Motor Protection Circuit Breaker (MPCB) GV2-ME20C / 13-18 A Thermal Protection Adjustment Range: 13-18 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	Motor Protection Circuit Breaker (MPCB) Model: GV2-ME20C / 13-18 A Thermal Protection Adjustment Range: 13-18 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	



SL	Name	Specification	Sample Picture
1	2	3	6
17	Motor Protection Circuit Breaker (MPCB) GV2-ME21C / 17-23 A, Thermal Protection Adjustment Range: 17-23 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA		
18	Leakage clamp on meter	Leakage clamp on meter Model 369 FC Manufacturer: Fluke	
19	Electric tester pen	Electric tester pen Model No: 66-119 Screw Drive Type Size: 3 mm x 50 mm Color: Yellow Test Range - 100 V - 500. Brand: Stanley	
20	Inspection Torchlight (Rechargeable)	Inspection Torchlight (Rechargeable) Model: F1P Rechargeable Battery: Rechargeable battery that integrates a Type-C interface for charging IP Rating: IPX7 Brand: BEEFLY/Equivalent	



SL	Name	Specification	Sample Picture
1	2	3	6
21	Motor Circuit Breaker GV3P 50 / 37-50 A	Motor Circuit Breaker GV3P 50 / 37-50 A Thermal Protection Adjustment Range: 37-50 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
22	Magnetic contactor	Magnetic contactor Model: LC1D410 C Rated Current: 410 A Coil Voltage: 24V DC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	
23	Magnetic contactor	Magnetic contactor Model: LC1D40 Rated Current: 40 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	
24	Magnetic contactor	Magnetic contactor Model: LC1D40A Rated Current: 40 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China	



SL	Name	Specification	Sample Picture
1	2	3	6
25	Magnetic contactor	<p>Magnetic contactor Model: LC1D95 Rated Current: 95 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China</p>	
26	Magnetic contactor	<p>Magnetic contactor Model: LC1D170 Rated Current: 170 A Coil Voltage: 240V AC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: China</p>	
27	Signal Fuse	<p>Fuse Signal Breaker Model: RX1D 1000 Breaker UN-1000V Brand: Shanghai Electrical Ceramics Factory Co. Ltd.,</p>	
28	Magnetic Contactor	<p>Magnetic Contactor Model: CAD32 BD Rated Current: 32 A Coil Voltage: 24V DC No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA</p>	



SL	Name	Specification	Sample Picture
1	2	3	6
29	Limit Switch	Limit Switch Model: WLCA2-G-N Brand: Omron	
30	Three-phase circuit breaker	Three Phase Circuit Breaker Model: EA9AN3D63 3P 63A D type Brand: Schneider Electric Country Origin: Europe / USA	
31	AC contactor	AC contactor Model: LC1D50B7C Rated Current: 50A Coil Voltage: 24V AC All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Czech Republic	单位:mm 手工测量，存在些许误差，请以实物为准 LC1D50 50A接触器
32	Motor Circuit Breaker	Motor Circuit Breaker GV3P65 / 48-65A Thermal Protection Adjustment Range: 48-65 A No of Pole: 3 All Screw and Contact Should be of copper Brand: Schneider Electric Country Origin: Europe / USA	
33	Angle grinder	Angle grinder Model: GWS1400-150 Input power: 1380W Grinding/slicing diameter: 150mm no-load speed: 9300 revolutions per minute Brand: Bosch Country Origin: Germany	

